



CABLE INSULATION POWER FACTOR TESTS



OWNER Example Owner PAGE 1
 PLANT Example Plant AMBIENT TEMP. _____ °F DATE 10/10/2014
 SUBSTATION CABLES HUMIDITY _____ % JOB # CABLES
 POSITION AUTOMATED ASSET ID _____

CABLE NAMEPLATE

MFR. AND TYPE _____ LOCATION _____ IDENTIFICATION _____
 RATED kV _____ OPERATING kV _____ AMPS (LOAD) _____ LENGTH - OUTDOOR _____ LENGTH - INDOOR _____
 AGE _____ TYPE _____ NUMBER OF CONDUCTORS _____ SIZE _____
 INSULATION MATERIAL _____ INSULATION THICKNESS _____ INSULATION TYPE _____
 JACKET _____ DUCT TRAY _____ CIRCUIT _____ WEATHER _____
 EARTH TEMP. _____ DUCT TEMP. _____ DEPTH _____

TEST FREQUENCY: 60

MULTIPLE QUICK TESTS

TEST NO	INSULATION TESTED	TEST MODE	SUPPRESS.	TEST kV	Test Freq	L(H) CAP.(pF)	POWER FACTOR %			DIRECT		%VDF	IR
							MEAS.	@ 20°C	CORR.	mA	WATTS		
1		UST-R	On						1.000				

INSULATION RATING KEY (IR)

- G = GOOD
- D = DETERIORATED
- I = INVESTIGATE
- B = BAD
- Q = QUESTIONABLE

COMMENTS: _____
 DEFICIENCIES: _____

TEST EQUIPMENT USED: _____ TESTED BY: Default Administrator

Serial Number: _____ Firmware Information: _____ Calibration Date: _____



CABLE POLARIZATION INDEX (PI) TEST



OWNER Example Owner PAGE 2
 PLANT Example Plant AMBIENT TEMP. _____ °F DATE 10/10/2014
 SUBSTATION CABLES HUMIDITY _____ % JOB # CABLES
 POSITION AUTOMATED ASSET ID _____

CABLE SOURCE _____ CABLE TERMINATION POINT _____
 OPERATING VOLTAGE _____ kV INSTALLED IN _____ LENGTH _____ FT
 MANUFACTURER _____ INSULATION TYPE _____ INSULATION THICKNESS _____ MILS
 SIZE _____ KCMIL NO. OF CONDUCTORS _____ CONDUCTOR MATERIAL _____
 RATED VOLTAGE _____ kV GROUNDED UNGROUNDED BELTED SHIELDED AGE _____
 PHASE IDENTIFICATION: PHASE A _____ PHASE B _____ PHASE C _____

CONNECTED EQUIPMENT _____ CABLE TEMPERATURE _____ °C
 TEST VOLTAGE _____ kVDC Enter TCF Manually: TEMPERATURE CORRECTION FACTOR TO 20°C, TCF _____
 K = INSULATION RESISTANCE CONSTANT IN MEGOHMS 20,000 TEST CONDUCTED BEFORE AFTER HIGH POTENTIAL TEST
 D = OUTSIDE DIAMETER OF INSULATION _____

$$R = [K \log_{10} \left(\frac{D}{d} \right)] \left(\frac{1000}{L \text{ (ft)}} \right)$$
 Use Instrument PI Value:

MINUTES	PHASE A MEGOHMS			PHASE B MEGOHMS			PHASE C MEGOHMS		
	READING (megohms)	TEMP. CORR. FACTOR	20°C READING (megohms)	READING (megohms)	TEMP. CORR. FACTOR	20°C READING (megohms)	READING (megohms)	TEMP. CORR. FACTOR	20°C READING (megohms)
0.25									
0.50									
0.75									
1.00									
2.00									
3.00									
4.00									
5.00									
6.00									
7.00									
8.00									
9.00									
10.00									
P.I.									

POLARIZATION INDEX = 10 MINUTE READING / 1 MINUTE READING
 * MINIMUM DESIGN INSULATION RESISTANCE, R = _____ MEGOHMS
Press F1 for form help


TEST EQUIPMENT USED: _____ TESTED BY: Default Administrator



CABLE POLARIZATION INDEX (PI) TEST



POLARIZATION CURVE



- Phase A: Red Square
- Phase B: Blue Circle
- Phase C: Green Triangle

COMMENTS:

DEFICIENCIES:



TIME DOMAIN REFLECTOMETER



OWNER Example Owner

PAGE 4

PLANT Example Plant

AMBIENT TEMP. _____ °F

DATE 10/10/2014

SUBSTATION CABLES

HUMIDITY _____ %

JOB # CABLES

POSITION AUTOMATED

ASSET ID _____

Select the Memory Locations to Download

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15

MEMORY LOCATION	WAVE TYPE	METER RANGE	PULSE WIDTH (ns)	GAIN (dB)	VELOCITY FACTOR	TRACE STYLE	DATE
-----------------	-----------	-------------	------------------	-----------	-----------------	-------------	------

COMMENTS: _____
 DEFICIENCIES: _____

TEST EQUIPMENT USED: _____

TESTED BY: Default Administrator



VLF CABLE TEST



OWNER Example Owner PAGE 5
 PLANT Example Plant AMBIENT TEMP. _____ °F DATE 10/10/2014
 SUBSTATION CABLES HUMIDITY _____ % JOB # CABLES
 POSITION GENERAL ASSET ID _____

OPERATING VOLTAGE _____ kV INSTALLED IN CONDUIT TRAY LENGTH _____ FT CABLE TEMPERATURE _____ °C
 MANUFACTURER _____ INSULATION TYPE _____ INSULATION THICKNESS _____ MILS
 SIZE _____ MCM NO. OF CONDUCTORS _____ CONDUCTOR MATERIAL CU AL
 RATED VOLTAGE _____ kV GROUNDED SHIELDED BELTED AGE _____
 UNGROUNDED UNSHIELDED (PILC)
 RESISTANCE GROUND CONCENTRIC NEUTRAL
 CABLE SOURCE _____ CABLE TERMINATION POINT _____
 CONNECTED EQUIPMENT _____ ISOLATE CABLE Y N ARRESTERS POT FUSES
 NUMBER OF MANHOLES _____ NUMBER OF TERMINATIONS _____ NUMBER OF SPLICES _____
 TERMINATION / SPLICES HAND TAPED 3-M TERM. KIT RAYCHEM KIT OTHER _____

RMS TEST VOLTAGE _____ kV BREAKDOWN YES NO PLANNED TEST DURATION _____ START TIME _____
 TEST FREQUENCY _____ Hz TIME TO FAILURE _____ MIN 1 MIN 15 MIN 30 MIN 60 MIN
 SHIELD RESISTANCE A-B _____ OHMS B-C _____ OHMS C-A _____ OHMS
 WAVE SHAPE SINE COSINE / RECTANGULAR OTHER _____ END TIME _____
 TEST TYPE WITHSTAND PASS / FAIL DIAGNOSTIC SEE COMMENT BELOW

PHASE A OR PHASE A, B, C

PHASE B

PHASE C

TESTS (MINUTES)	<input type="checkbox"/> PHASE A OR <input type="checkbox"/> PHASE A, B, C			<input type="checkbox"/> PHASE B			<input type="checkbox"/> PHASE C		
	MEGOHMS	NANO FARADS	MICRO AMPS	MEGOHMS	NANO FARADS	MICRO AMPS	MEGOHMS	NANO FARADS	MICRO AMPS
1									
5									
10									
15									
20									
25									
30									
45									
60									

COMMENTS: _____
 DEFICIENCIES: _____

TEST EQUIPMENT USED: _____ TESTED BY: Default Administrator



TAN DELTA CABLE TEST



OWNER Example Owner
 PLANT Example Plant
 SUBSTATION CABLES
 POSITION GENERAL

PAGE 8
 AMBIENT TEMP. _____ °F
 DATE 10/10/2014
 HUMIDITY _____ %
 JOB # CABLES
 ASSET ID _____

OPERATING VOLTAGE _____ kV INSTALLED IN CONDUIT TRAY LENGTH _____ FT CABLE TEMPERATURE _____ °C
 MANUFACTURER _____ INSULATION TYPE _____ INSULATION THICKNESS _____ MILS
 SIZE _____ MCM NO. OF CONDUCTORS _____ CONDUCTOR MATERIAL CU AL
 RATED VOLTAGE _____ kV GROUNDED SHIELDED BELTED (PILC) AGE _____
 UNGROUNDED UNSHIELDED
 RESISTANCE GROUND CONCENTRIC NEUTRAL
 CABLE SOURCE _____ CABLE TERMINATION POINT _____
 CONNECTED EQUIPMENT _____ ISOLATE CABLE Y N ARRESTERS POT FUSES
 NUMBER OF MANHOLES _____ NUMBER OF TERMINATIONS _____ NUMBER OF SPLICES _____
 TERMINATION / SPLICES HAND TAPED 3-M TERM. KIT RAYCHEM KIT OTHER _____

SYSTEM VOLTAGE _____ BREAKDOWN YES NO PLANNED TEST DURATION PER STEP START TIME
 TEST FREQUENCY _____ TIME TO FAILURE _____ MIN 1 MIN 5 MIN 10 MIN
 WAVE SHAPE SINE COSINE / RECTANGULAR OTHER _____ END TIME
 TEST TYPE WITHSTAND PASS / FAIL DIAGNOSTIC _____

PHASE A OR PHASE A, B, C PHASE B PHASE C

TEST VOLTAGE kV		TAN DELTA	NANO FARADS	MICRO AMPS	TAN DELTA	NANO FARADS	MICRO AMPS	TAN DELTA	NANO FARADS	MICRO AMPS
5kV CABLE	15 kV CABLE									
1.0	2									
1.5	3.5									
2.0	5									
2.4	7									

COMMENTS: _____
 DEFICIENCIES: _____

TEST EQUIPMENT USED: _____ TESTED BY: Default Administrator



SWITCHBOARD BUS CONNECTION TEST



OWNER Example Owner
 PLANT Example Plant
 SUBSTATION CABLES
 POSITION GENERAL

PAGE 9
 AMBIENT TEMP. _____ °F
 DATE 10/10/2014
 HUMIDITY _____ %
 JOB # CABLES
 ASSET ID _____

NAMEPLATE DATA

MANUFACTURER _____ SERIAL NO. _____ TYPE _____
 CATALOG NO. _____ DRAWING NO. _____ VOLTAGE CLASS _____
 PHASE AMPACITY _____ A WITHSTAND RATING _____ KA CONDUCTOR CU AL

IDENTIFICATION	FROM	RESISTANCE IN MICRO-OHMS				
	TO	A	B	C	N	G

COMMENTS: _____
 DEFICIENCIES: _____

TEST EQUIPMENT USED: _____ TESTED BY: Default Administrator



LOW VOLTAGE CABLE INSULATION TEST



OWNER Example Owner
 PLANT Example Plant
 SUBSTATION CABLES
 POSITION GENERAL

PAGE 10
 DATE 10/10/2014
 AMBIENT TEMP. _____ °F
 HUMIDITY _____ %
 JOB # CABLES
 ASSET ID _____

MANUFACTURER _____ DATE MANUFACTURED _____
 INSULATION TYPE 1: TW THW THHW XHHW THHN
 INSULATION TYPE 2: RH RHW
 EQUIPMENT TEMPERATURE _____ °C
 OTHER _____

TEST VOLTAGE _____ kVDC TEMPERATURE CORRECTION FACTOR TO 20°C, TCF _____ INS. TYPE 1 _____ INS. TYPE 2 _____

IDENTIFICATION	NO. & COND. SIZE	FROM		PHASE									
		TO		A - GND	B - GND	C - GND	N - GND	A - B	B - C	C - A	A - N	B - N	C - N
			RDG										
			20°C										
			RDG										
			20°C										
			RDG										
			20°C										
			RDG										
			20°C										
			RDG										
			20°C										
			RDG										
			20°C										
			RDG										
			20°C										

ALL INSULATION VALUES ARE IN MEGOHMS

COMMENTS: _____
 DEFICIENCIES: _____

TEST EQUIPMENT USED: _____ TESTED BY: Default Administrator



CABLE HIGH POTENTIAL TEST AND INSULATION RESISTANCE




OWNER Example Owner
 PLANT Example Plant
 SUBSTATION CABLES
 POSITION GENERAL

PAGE 11
 AMBIENT TEMP. _____ °F DATE 10/10/2014
 HUMIDITY _____ % JOB # CABLES
 ASSET ID _____

CABLE SOURCE _____ CABLE TERMINATION POINT _____
 OPERATING VOLTAGE _____ kV INSTALLED IN _____ LENGTH _____ FT
 MANUFACTURER _____ INSULATION TYPE _____ INSULATION THICKNESS _____ MILS
 SIZE _____ KCMIL NO. OF CONDUCTORS _____ CONDUCTOR MATERIAL _____
 RATED VOLTAGE _____ kV GROUNDED UNGROUNDED BELTED SHIELDED AGE _____

CONNECTED EQUIPMENT _____

TIME MINUTES	TEST kV	PHASE A μ A	PHASE B μ A	PHASE C μ A
0.25				
0.50				
0.75				
1.00				
1.25				
1.50				
1.75				
2.00				
3.00				
4.00				
5.00				
6.00				
7.00				
8.00				
9.00				
10.00				
11.00				
12.00				
13.00				
14.00				
15.00				
16.00				
17.00				
18.00				
19.00				
20.00				
21.00				
22.00				
23.00				
24.00				
25.00				
DECAY TO 5kV; SECS				
SHIELD RESIST.- OHMS				
INSULATION RESISTANCE		GIGA-OHMS @ _____ kV		
		0.000	0.000	0.000



COMMENTS: _____
 DEFICIENCIES: _____

TEST EQUIPMENT USED: _____ TESTED BY: Default Administrator



CABLE HIGH POTENTIAL TEST




OWNER Example Owner
 PLANT Example Plant
 SUBSTATION CABLES
 POSITION GENERAL

PAGE 12
 AMBIENT TEMP. _____ °F DATE 10/10/2014
 HUMIDITY _____ % JOB # CABLES
 ASSET ID _____

CABLE SOURCE _____ CABLE TERMINATION POINT _____
 OPERATING VOLTAGE _____ kV INSTALLED IN _____ LENGTH _____ FT
 MANUFACTURER _____ INSULATION TYPE _____ INSULATION THICKNESS _____ MILS
 SIZE _____ KCMIL NO. OF CONDUCTORS _____ CONDUCTOR MATERIAL _____
 RATED VOLTAGE _____ kV GROUNDED UNGROUNDED BELTED SHIELDED AGE _____

CONNECTED EQUIPMENT _____

TIME MINUTES	TEST VOLTAGE	PHASE A μA	PHASE B μA	PHASE C μA
0.25				
0.50				
0.75				
1.00				
1.25				
1.50				
1.75				
2.00				
3.00				
4.00				
5.00				
6.00				
7.00				
8.00				
9.00				
10.00				
11.00				
12.00				
13.00				
14.00				
15.00				
16.00				
17.00				
18.00				
19.00				
20.00				
21.00				
22.00				
23.00				
24.00				
25.00				
DECAY TO 5kV; SECS				
SHIELD RESIST.- OHMS				



COMMENTS: _____
 DEFICIENCIES: _____

TEST EQUIPMENT USED: _____ TESTED BY: Default Administrator